

EG-Baumusterprüfbescheinigung

EC type examination certificate

CE-0085BS0132

Produkt-Identnummer
product identification no.

Anwendungsbereich <i>field of application</i>	EG-Gasgeräte-richtlinie (90/396/EWG) EC Gas Appliances Directive (90/396/EEC)
Zertifikatinhaber <i>owner of certificate</i>	Remeha B.V. Kanaal Zuid 110, NL-7300 AA Apeldoorn
Vertreiber <i>distributor</i>	Remeha B.V. Kanaal Zuid 110, NL-7300 AA Apeldoorn
Produktart <i>product category</i>	Boilers with flue systems: Condensing water heater (3202)
Produktbezeichnung <i>product description</i>	floor standing gas fired central heating condensing boiler
Modell <i>model</i>	Gas 210 ECO PRO ...
Bestimmungsländer <i>countries of destination</i>	AT, BE, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, RU, SE, SI, SK, TR, UA
Prüfberichte <i>test reports</i>	type testing: K1892007B8 from 28.11.2007 (TRG) type testing: K1892007T2 from 02.08.2007 (TRG) type testing: K1892007B3 from 14.05.2007 (TRG)
Prüfgrundlagen <i>basis of type examination</i>	EU/90/396/EWG (29.06.1990) DIN EN 15417 (01.11.2006) DIN EN 15420 (draft 01.01.2006) DIN EN 656/A1 (01.12.2006)
Aktenzeichen <i>file number</i>	06-0846-GEE



04.12.2007 Rie A-1/2


Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Bundesregierung benannte und von der Europäischen Kommission offiziell registrierte Stelle für die Konformitätsbewertung von Gasgeräten

DVGW CERT GmbH - notified by the government of the Federal Republic of Germany and officially registered by the European Commission for conformity assessment of gas appliances



ZLS-ZE-527/07

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888

Telefax: +49 228 91 88-993

eMail: info@dvgw-cert.com

Elektrische Daten: 230 V AC, 50 Hz
electrical data

Gerätekatategorien <i>appliance categories</i>	Versorgungsdrücke <i>supply pressures</i>	Bestimmungsländer <i>countries of destination</i>	Bemerkungen <i>remarks</i>
I2E	20 mbar	LU, PL	
I2E(R)B	20/25 mbar	BE	
I2ELL	20 mbar	DE	
I2H	20 mbar	DK, EE, FI, IS, LT, LV, NO, SE	
I2HS	25 mbar	HU	
I3P	30 mbar	DK, EE, FI, IS, NL, NO, SE	
I3P	37 mbar	BE, LT, MT, PL	
I3P	50 mbar	BE, DE, HU, LU, NL	
II2E3P	20, 37 mbar	PL	
II2E3P	20, 50 mbar	LU	
II2ELL3P	20, 50 mbar	DE	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	DK, EE, FI, IS, NO, RO, SE	
II2H3P	20, 37 mbar	CH, CZ, ES, GB, GR, IE, IT, LT, PT, SI, SK, TR	
II2H3P	20, 50 mbar	AT, CZ, SK	
II2HS3P	25, 50 mbar	HU	
II2L3P	25, 30 mbar	NL	
II2L3P	25, 50 mbar	NL	

Typ <i>type</i>	Technische Daten <i>technical data</i>	Bemerkungen <i>remarks</i>
Gas 210 ECO PRO 80	heat output: 16...87 kW heat input (Hi): 17...89 kW	
Gas 210 ECO PRO 120	heat output: 22...120 kW heat input (Hi): 23...123 kW	
Gas 210 ECO PRO 160	heat output: 29...166 kW heat input - natural gas (Hi): 31...170 kW heat input - LPG (Hi): 44...170 kW	
Gas 210 ECO PRO 200	heat output: 39...200 kW heat input (Hi): 41...205 kW	

Verwendungshinweise / Bemerkungen *hints of utilization / remarks*

flue types B23, B23P, C13, C33, C33S, C43, C53, C63 (not for BE) and C83: according to "Technical Information" no. 114493-140607 with flue systems Mugro manufactured by Muelink & Grol with the approvals no. 0432-BPR-2205 and 0432-BPR-119940 and flue system T250 manufacturee by Cox Geelen with the approval no. 0063-CPD-6607

Additional tested countries of destination, appliance categories and supply pressures:

UA: I2H (20 mbar)

NL: I2H (25 mbar)

BY, CY, HR, RU: II2H3P (20, 37 mbar)

BG, BY, CY, HR, RU: II2H3P (20, 50 mbar)

In Belarus, Croatia, Ukraine and in the Russian Federation the CE-marking will be accepted as conformaty approval if the Gas Appliance Directive (90/396/EEC) is transferred into national law by Belarus, Croatia, Ukraine respectively by the Russian Federation.

